



RK Occupational & Environmental Analysis Inc.

401 St. James Ave. Phillipsburg, N.J. 08865
Telephone: 908-454-6316 Fax: 908-454-4818
rkenvironmental@entemail.net

Mold Assessment
and Remediation

June 30, 2025

Health/Safety and
Environmental
Regulatory
Compliance

Mr. Steve Lemoine
Supervisor of Buildings & Grounds
White Township Board of Education
565 Route 519
Belvidere, NJ 07823

Right-To-Know

re: **Water Sampling for Compliance with N.J.A.C. 6A:26-12.4
Lead in Drinking Water**

OSHA/EPA/DOT
Training Programs

Dear Mr. Lemoine,

Asbestos and Lead
Management

We enclose the following documents and related information for compliance with the NJ Department of Education Regulation related to Lead in Drinking Water in school buildings:

Industrial Hygiene/
OSHA Compliance

Sampling Report Narrative	3 pages
Water Sampling Log and Results	2 pages
Laboratory Analytical Report (electronic copy only)	20 pages

Indoor Air Quality

No sample result exceeded the NJ Standard of 0.015 mg/L for Lead in Drinking Water. This report along with the laboratory results should be updated on the District's website.

Underground/
Aboveground
Storage Tanks

If you have any questions, please don't hesitate to call us.

Environmental
Site Assessment

Sincerely,

Patrick D. McGuinness, MS, P.E.
Vice President

Hazardous/
Medical Waste
Management

PDM/

(file \Reports\Watertest\White-251)

Environmental
Audits

Expert Witness/
Litigation Support

Customized
Software

Sampling Report - Lead in Drinking Water
White Township School District

1. Sampling Results Summary and Statistics

Sample Collection Date	May 20, 2025
Number of Buildings Sampled	1
Total Number of Samples Collected	13
Number of Samples with No Detectible Lead	11
Number of Samples Exceeding 15 ppb (0.015 mg/L Standard)	0
Number of Samples Exceeding 5 ppb (0.005 mg/L EPA threshold)	1
Highest Measured Lead Content (ppb)	0.012

2. Water Sampling Procedures

Sampling protocols and procedures follow the EPA “3-T’s Program” that was developed for schools and Child Care centers. They recognize that the typical school building is actually a conglomeration of an original building with one or more additions, each of which typically having different plumbing system materials.

In addition, building sections constructed before 1986 likely have plumbing systems that used leaded solders on Copper water lines. Very old buildings and public water supply systems may also still have lead piping. Other potential sources of Lead in drinking water systems include brass faucets, fittings, along with valve seats and stems that are used in the municipal and building piping distribution systems. It is important to note that “Lead-Free” plumbing components used since 1986 may actually contain up to 8% Lead by weight. In January 2014, this limit was lowered from 8% to 0.2% Lead.

The sampling protocol requires that water be collected as a “First-Draw” to ensure that the water sample has been standing for at least 8 hours. This is intended to replicate a “worst-case” situation since both the Lead levels are usually lowered significantly after running the water even for a few moments.

Drinking water samples were collected early on a weekday (not Monday) or Saturday morning before staff and students arrived for classes to represent water that has sat idle in the building piping system overnight.

All samples were collected in 250 ml contaminant-free containers. Laboratory analysis of the water samples was performed by Pace Analytical Services, LLC of Fairfield, NJ (NJ DEP

Certification Nos. NJ 07010). The analytical method is per EPA Method 200.8 via atomic absorption, induction coupled plasma technique. Contaminant-free sampling bottles are provided by the laboratory and are pre-filled with a Nitric Acid preservative that keep the dissolved compounds in suspension until laboratory analysis.

3. Sample Results and Discussion

Sampling results are discussed below and the sampling log is appended to this report. It is important to note that the laboratory results are reported in terms of milligrams per liter (mg/L). The Action Level for Lead in Drinking Water is 0.015 mg/L. This also translates to 15 parts of Lead per billion (ppb) parts of water.

A total of 13 water samples were collected on May 20, 2025. None of the samples exceeded the 0.015 mg/L standard for Lead in Drinking Water. In fact, 11 of the 13 water samples had detectible levels of Lead present just below the standard.

4. Recommendations and Future Work

All water sample results showed acceptable results for Lead content. The following responses include those required by N.J.A.C. 6A:26-12.4 and our recommendations to maintain the drinking water quality as it relates to Lead contamination.

The NJDOE regulations requires that:

- These sampling results be made publically available at the school building and on the School District's website.
- The School District shall collect drinking water samples and analyze for Lead at any drinking water outlet that has been replaced or after any alterations to the plumbing or service lines to the outlet. Do not consume or cook with water from the affected outlet until acceptable Lead results are obtained.
- Repeat water sampling within 3 years of the date of this sampling or before May 2025.

In addition, we suggest that the following responses to minimize the potential for Lead contamination of drinking water:

Administrative Responses:

- There are several factors that influence the potential for Lead corrosion in drinking water piping systems. These include the chemistry of the water supplied being supplied to the building, water temperature and velocity through the piping, the age and condition of the plumbing, and the amount of time the water sits "stagnant" in contact with piping and


drinking water fixtures. This last factor is the only one that a building owner has any control of.

- School building codes require a minimum of one (1) drinking water tap for every 100 students of building capacity. Wherever a larger number of water taps exists, the usage factor for each tap decreases. This, in turn, increases the "stagnation time" along with the increased potential for Lead corrosion. It is recommended that the need for all current water taps be investigated and reduced where appropriate while maintaining the minimum of 1 tap per 100 students.
- Consider implementing a program to shut-off and replace (if needed) any drinking water fixture of appliance that is more than 35 years old (was installed before the 1986 Lead Ban took effect).

Operational and Maintenance Responses:

- EPA recommends that any water tap where the measured Lead content exceeds 5 parts per billion (PPB) or 5 µg/L be inspected and cleaned of line sediment to eliminate potential sources of Lead contamination. There were 1 water samples above this level.
- Use cold water only for drinking or cooking. Higher water temperatures will increase the water's corrosion potential.
- The accumulation of line sediment on aerators and screens at the water taps is frequently the source of high levels of Lead. It is recommended that a program be established to regularly inspect for the presence of line sediment at all drinking water taps. Initially, an annual inspection is suggested. The inspection frequency should then be adjusted depending upon the amounts of sediment that is found and where it is found. Higher usage taps may accumulate sediment more quickly and need to be cleaned more often.
- It is known that flushing water through drinking water taps will reduce the levels of both Lead and Copper present in the drinking water. It is also recommended that a program be established to run water at all drinking or cooking taps for at least one minute before students and staff return to school after long breaks, especially after the Summer recess.

Report prepared by:



Patrick D. McGuinness, MS, P.E.

Vice President

Water Sampling Log

Name of Building:
Building Owner:

White Township School
White Township Bd of Educ

Date Collected: 20-May-25
Sample Collected by: PD McGuinness

Sample No.	Tap No.	Sample Type	Type of Outlet	Manufacturer	Sample Location	Time	Lead Results	
							mg/L	%AL
	1	1st	Sink		Teacher's Room 14B ** Used for Washup Only **		no sample	
RK-051525-01	2	1st	Bottle Filler/Bubbler	Elkay	Cafeteria 11B	06:29	ND	-
	3	1st	Bubbler		Cafeteria 11B ** Removed **		no sample	
	4	1st	Sink		Kitchen 12B - Hand Sink ** Used for Washup Only **		no sample	
	5	1st	Sink		Kitchen 12B - Main Sink ** Used for Washup Only **		no sample	
RK-051525-02	6	1st	Pot Filler		Kitchen 12B - Pot Filler	06:32	0.0120	80%
RK-051525-03	7	1st	Bottle Filler/Bubbler	Elkay	Hallway - by closet 111	06:34	ND	-
RK-051525-04	8	1st	Bottle Filler/Bubbler	Elkay	Hallway - by closet 151	06:36	ND	-
RK-051525-05	9	1st	Sink		Room 190	06:38	0.0023	15%
	10	1st	Bubbler		Room 200 ** Removed **		no sample	
	11	1st	Bubbler		Room 210 ** Removed **		no sample	
	12	1st	Bubbler		Room 230 ** Removed **		no sample	
	13	1st	Bubbler		Room 240 ** Removed **		no sample	
	14	1st	Bubbler		Room 250 ** Removed **		no sample	
RK-051525-06	15	1st	Bottle Filler/Bubbler	Elkay	Hallway - by Room 300	06:41	ND	-
	16	1st	Chiller	Halsey Taylor	Hallway - by Room 360B ** Removed **		no sample	
RK-051525-07	17	1st	Sink		Office Workroom	06:43	ND	-
RK-051525-08	18	1st	Sink		Nurse's Office - Front Room	06:45	ND	-
RK-051525-09	19	1st	Sink		Nurse's Office - Side Room	06:46	ND	-
RK-051525-10	20	1st	Chiller	Elkay	Hallway - by Gym, left side	06:49	ND	-

Sample Type:

1st: First Draw sample collected after water sat in pipe between 8 and 18 hours

Bottle Filler/Bub: optical bottle filler and bubbler outlets

ND: means Not Detected at or above the Reliability Detection Limit (RDL) of 0.0020 mg/L for Lead.

Water Sampling Log

Name of Building:
Building Owner:

White Township School
White Township Bd of Educ

Date Collected: _____
Sample Collected by: _____

20-May-25

PD McGuinness

[illegible]

Sample Type:

1st: First Draw sample collected after water sat in pipe between 8 and 18 hours

Bottle Filler/Bub: optical bottle filler and bubbler outlets

ND: means Not Detected at or above the Reliability Detection Limit (RDL) of 0.0020 mg/L for Lead.

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

CERTIFICATE OF ANALYSIS

Pat McGuinness

RK Occupational & Environmental

Analysis, Inc.

401 St. James Avenue

Phillipsburg, NJ 08865

Project Name and Number:

White Twp School District

Workorder:

25F1685

Purchase Order:

June 30, 2025

This report relates only to the sample(s) as received by the laboratory on June 13, 2025. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your Pace Analytical Services, LLC-Fairfield project coordinator.

Note: This cover page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Timothy Swavely For Mary Ellen Nealy, Project
Coordinator

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-01 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:29
Sample ID: RK-051525-01 (Cafeteria 11B) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 12:10	06/30/2025 12:10	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-02 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:32
Sample ID: RK-051525-02 (Kitchen 12B - Pot Filler) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.0120		mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 11:41	06/30/2025 11:41	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-03 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:34
Sample ID: RK-051525-03 (Hallway - by closet 111) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 11:46	06/30/2025 11:46	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-04 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:36
Sample ID: RK-051525-04 (Hallway - by closet 151) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 11:51	06/30/2025 11:51	1



Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-05 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:38
Sample ID: RK-051525-05 (Room 190) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00231		mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 04:54	06/30/2025 04:54	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-06 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:41
Sample ID: RK-051525-06 (Hallway - by Room 300) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 04:59	06/30/2025 04:59	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-07 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:43
Sample ID: RK-051525-07 (Office Workroom) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 05:03	06/30/2025 05:03	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-08 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:45
Sample ID: RK-051525-08 (Nurse Office - Front Room) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 05:06	06/30/2025 05:06	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-09 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:46
Sample ID: RK-051525-09 (Nurse Office - Side Room) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 05:10	06/30/2025 05:10	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-10 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:49
Sample ID: RK-051525-10 (Hallway - by Gym, left side) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 05:14	06/30/2025 05:14	1



Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-11 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:52
Sample ID: RK-051525-11 (Hallway - by Gym, center) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 05:18	06/30/2025 05:18	1



Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-12 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:52
Sample ID: RK-051525-12 (Hallway - by Gym, right side) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 05:23	06/30/2025 05:23	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Lab ID: 25F1685-13 **Matrix:** Drinking Water **Date Collected:** 05/20/2025 06:54
Sample ID: RK-051525-13 (MD Room 520) **Date Received:** 06/13/2025 13:58

Total Metals - Pace Analytical Services, LLC-Fairfield

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	06/30/2025 05:38	06/30/2025 05:38	1

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Qualifiers

U Compound not detected

Abbreviations

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTL	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

Pace Analytical Services, LLC-Fairfield
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004
(P) (973) 227-0422 - www.pacelabs.com

Laboratory Certification List for this report.

Laboratory	Certification				
	NJ	NY	PA	CT	
Pace Analytical Services, LLC Ewing 812 Silvia Street Ewing, NJ 08628	11005	12046	68-05417		
Pace Analytical Services, LLC-Fairfield 1275 Bloomfield Ave, Ste 37D Fairfield, NJ 07004	07010	11634	68-02903		



Pace* Location Requested (City/State):

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: RK Occupational & Environmental Analysis, Inc.
Street Address: 401 St James Avenue, Phillipsburg, NJ 08865

Contact/Report To: PD McGuinness
Phone #: 908-454-6316
E-Mail: pdmcguinness@enter.net
Cc E-Mail: rkenvironmental@entermail.net

Customer Project #: 25-038
Project Name: White Twp School District

Invoice To: PD McGuinness
Invoice E-Mail: pdmcguinness@enter.net
Purchase Order # (if applicable):
Quote #: 154040

Site Collection Info/Facility ID (as applicable):

Drinking Water Sampling for Lead

Time Zone Collected: [] AK [] PT [] MT [] CT [] ET [] New Jersey

Data Deliverables:
Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [] Yes [] No
NIAC: 6A:26-12.4 Sampling for Lead in Drinking Water

[X] Level II [] Level III [] Level IV
[] EQUIS [] Other
Rush (pre-approval required): DW PWSID # or WW Permit # as applicable:
[] Same Day [] 1 Day [] 2 Day [] 3 Day [] Other

Date Results Requested:
Field Filtered (if applicable): [] Yes [] No
Analysis:

* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SD), Sludge (SL), Cavity (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite start		Collected or Composite end		Cont. #	Results	Units
			Date	Time	Date	Time			
Please refer to attached Water Sampling Log	DW	Grab	all samples				1 ea		
for sample date, times, and locations			2 pages						
			Z-sided						
Total of 13 water samples									

Water Sampling Log

Name of Building: White Township School Date Collected: 20-May-25
 Building Owner: White Township Bd of Educ Sample Collected by: PD McGuinness

Sample No.	Tap No.	Sample Type	Type of Outlet	Manufacturer	Sample Location	Time	Lead Results	
							mg/L	%AL
--	1	1st	Sink		Teacher's Room 14B ** Used for Washup Only **		no sample	
RK-051525-01	2	1st	Bottle Filler/Bubbler	Elkay	Cafeteria 11B	06:29		-
--	3	1st	Bubbler		Cafeteria 11B ** Removed **		no sample	
--	4	1st	Sink		Kitchen 12B - Hand Sink ** Used for Washup Only **		no sample	
--	5	1st	Sink		Kitchen 12B - Main Sink ** Used for Washup Only **		no sample	
RK-051525-02	6	1st	Pot Filler		Kitchen 12B - Pot Filler	06:32		-
RK-051525-03	7	1st	Bottle Filler/Bubbler	Elkay	Hallway - by closet 111	06:34		-
RK-051525-04	8	1st	Bottle Filler/Bubbler	Elkay	Hallway - by closet 151	06:36		-
RK-051525-05	9	1st	Sink		Room 190	06:38		-
--	10	1st	Bubbler		Room 200 ** Removed **		no sample	
--	11	1st	Bubbler		Room 210 ** Removed **		no sample	
--	12	1st	Bubbler		Room 230 ** Removed **		no sample	
--	13	1st	Bubbler		Room 240 ** Removed **		no sample	
--	14	1st	Bubbler		Room 250 ** Removed **		no sample	
RK-051525-06	15	1st	Bottle Filler/Bubbler	Elkay	Hallway - by Room 300	06:41		-
--	16	1st	Chiller	Halsey Taylor	Hallway - by Room 360B ** Removed **		no sample	
RK-051525-07	17	1st	Sink		Office Workroom	06:43		-
RK-051525-08	18	1st	Sink		Nurse's Office - Front Room	06:45		-
RK-051525-09	19	1st	Sink		Nurse's Office - Side Room	06:46		-
RK-051525-10	20	1st	Chiller	Elkay	Hallway - by Gym, left side	06:49		-

Sample Type: **1st:** First Draw sample collected after water sat in pipe between 8 and 18 hours
Bottle Filler/Bub: optical bottle filler and bubbler outlets
ND: means Not Detected at or above the Reliability Detection Limit (RDL) of 0.0020 mg/L for Lead.

Name of Building:
Building Owner:

White Township School
White Township Bd of E

Date Collected: 20-May-25
Sample Collected by: PD McGuinne

[illegible]

Sample Type:

1st: First Draw sample collected after water sat in pipe between 8 and 18 hours

Bottle Filler/Bub: optical bottle filler and bubbler outlets

ND: means Not Detected at or above the Reliability Detection Limit (RDL) of 0.0020 mg/L for Lead.

Sample Condition Upon Receipt Form (SCUR)



Affix Sample | 25F1685

Date and Initials of person:
Examining contents: _____
Label: _____
Deliver to location: _____
pH: _____

Thermometer Used: 7ITR05 Date: 6/13/25 Time: 14:36 Initials: PAD

State of Origin: NJ

Cooler #1 Temp. °C 23.2 (Visual) 0 (Correction Factor) 23.2 (Actual) ☐ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☒ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground
☐ Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☒ No ☐ N/A

Comments:

Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Additional Login Comments: _____

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____
Comments/Resolution: _____